



**DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE
CHIEF WATER ANALYST'S LABORATORY, COIMBATORE - 18.**

From

Tmt. R. Malarvizhi, M.Sc., M.Ed.,
Chief Water Analyst,
219, Race Course Road,
Coimbatore 641 018,
Ph.No: 0422-2221542,
E.mail: cwadph.cbe@gmail.com.

To

RKS Vidyalaya,
91, Avinashi Road,
Coimbatore - 641 018.

R.No. 0835/ A3 / 2024 (437) CWA/CBE, M -173

Dated:23.04.2024.

Sir,

Sub: Report on Examination of water sample from RKS Vidyalaya,
91, Avinashi Road, Coimbatore, Collected on 17.04.2024.

A sample of water stated to have been collected on 17.04.2024 from the Water Doctor Outlet tap near the Library Block (Inside the School), RKS Vidyalaya, 91, Avinashi Road, Coimbatore, Source: Pillur Water – Corporation Supply by Ms.S.Sangeetha, SR Manager – HR & Admin was received at this laboratory on the same day from the above addressee to assess its suitability for drinking purpose.

The results of analysis are furnished overleaf.

The sample of water is Colourless and clear in physical appearance.

Judged by the results of analysis, it is of satisfactory Chemical and bacteriological quality for drinking purpose.

However the Water Doctor Unit should be maintained periodically as per the supplier's manual to get hygienic safe water at all times.

The Sump / OHT should be cleaned atleast once in a month to maintain the hygienic status.

**CHIEF WATER ANALYST,
COIMBATORE-18.**

Copy to Lab / File


24/11/24
24/04/24

DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

CHIEF WATER ANALYST'S LABORATORY, COIMBATORE-641018

RESULTS OF EXAMINATION OF SAMPLES OF WATER

Samples from	RKS Vidyalaya, 91, Avinashi Road, Coimbatore - 641 018.		
Collected by	Ms.S.Sangeetha, SR Manager - HR & Admin		
Date of collection:	17.04.2024		
Date of Receipt :	17.04.2024		
	M. 173		
Source as per Label	Water Doctor Outlet tap near the Library Block (Inside the school), RKS Vidyalaya, 91, Avinashi Road, Coimbatore.		
Source :	Pillur Water - Corporation Supply		
Bacteriological Examination			
Plate count per ml.on agar at 37 ^o .C-24 hrs	10		
MPN of Coliform bacteria/100ml	0		
Nature of Coliform bacteria isolated			
Results of Vibrio test			
Physical Examination			
Colour	Colourless		
Turbidity	1		
Smell	None		
Chemical Examination(in mg/l)			
Total solids	130		
Carbonate Hardness (as CaCO ₃)	60		
Non-carbonate Hardness(as CaCO ₃)	8		
Total Hardness (as CaCO ₃)	68		
Calcium Hardness (as CaCO ₃)	32		
Magnesium Hardness (as CaCO ₃)	36		
Chloride (as Cl)	13		
Ammonia cal Nitrogen (as N)	0		
Albuminoid Nitrogen (as N)	-		
Oxygen absorbed(Tidys test) in 4 hrs	0.12		
Nitrate nitrogen as N	0.5		
Acidity/Alkalinity} Phenolphthalein as CaCO ₃ } Methyl Orange	0 60		
Fluoride (as F)	0.2		
pH value	7.8		
Total Iron (as Fe)	0		
Manganese (as Mn)	0		
Qualitative Tests			
Nitrite Nitrogen	Trace		
Sulphate	Trace		
Phosphate	Trace		
Toxic Substance			
Electrical conductivity(Reciprocal megohms per cm at 20°C)	180		
Microscopical Examination	Amorphous Matter		


CHIEF WATER ANALYST,
COIMBATORE-18.
Ms. Sangeetha
 24/04/24



Coimbatore City Municipal Corporation

SANITARY CERTIFICATE

R.No. 10/2025/ME3 Date: 09.12.2025

Certified that M/s. RKS VIDYALAYA, No.91, Avinashi Road, Near Anna Statue, Coimbatore-641018. has been inspected by the sanitary inspector and the building and premises are found satisfactory on the following aspects.

1. The ventilation & Lighting facilities are satisfactory.
2. The building is maintained properly.
3. The rooms and surrounding are maintained neat and clean.
4. The sanitary arrangements provided are adequate and satisfactory.
5. The supply of drinking water is wholesome.

The sanitary certificate may be issued subject to the following conditions:

- ❖ The garbage generated within the building premises should be collected and disposed of properly by appointing required sanitary staff.
- ❖ On no account, the garbage should be burnt.
- ❖ The occupants should be educated to prevent the usage of plastics in the building premises and no one should bring plastic carry bags, use & throw tumblers to the rooms and should also be educated to keep our surroundings clean. One use plastic is banned strictly by the Tamil Nadu Government . So, ensure "Plastic Free" in your premises.
- ❖ The certificate issued is liable to be cancelled at any time on infringement of any of the above said conditions and for improper maintenances of sanitation, improper maintenance of the building as well as urinals and toilets in the building.
- ❖ Adequate fire safety precautions should be made and NOC should be obtained from Fire and Rescue Department.
- ❖ Safe and protected drinking water alone should be supplied to the children for consumption.
- ❖ The premises should be inspected periodically for mosquito breeding places and all measures should be taken to keep the premises mosquito free.
- ❖ For running a food establishment / canteen, permission should be obtained from the food safety department.
- ❖ Incinerator shall be installed for safe disposal of sanitary napkins.
- ❖ The lab in charge should be well trained in handling the fire extinguisher.
- ❖ 'No Smoking' board should be displayed at prominent places with in the premises.
- ❖ No account sale of tobacco products should be permitted within the premises.
- ❖ Any occurrence of communicable disease should be notified to the Public Health Department.
- ❖ Necessary building plan approval should be obtained from concerned department to run the Institution.
- ❖ All the staffs must be vaccinated with the two doses of COVID-19 vaccine and Should be follow up Tamilnadu government Standard operating Procedure(SOP)
- ❖ Valid for One Year Only.
- ❖ ISSUED ON 09/12/2025 VALID UPTO 09/12/2026



Zonal Sanitary Officer
Coimbatore Corporation

5.12
ZONAL SANITARY OFFICER
CENTRAL ZONE
COIMBATORE CITY
MUNICIPAL CORPORATION